


Declaration of conformity

Issued by
Rittal India Pvt. Ltd.
Bangalore – 561203

Quality Management

We here by confirm that all RITTAL PS standard Enclosures systems complies with requirement according to UL-50 type 12 and full fill protection category IP 55 according to EN 60529 “Degrees of protection provided by enclosures”.



Bangalore,
27.06.2015

A handwritten signature in blue ink, appearing to read "Girish Kumar.R".

Girish Kumar.R
Quality Assurance

Rittal India Pvt Ltd
No 23 & 24, KIADB Industrial Area
Veerapura, Doddaballapur – 561203
Telephone: +91 (80) 3372 0700
Fax: +91 (80) 2762 3343
E-mail: info@rittal-india.com
Internet : <http://www.rittal-india.com>

