



Underwriters Laboratories Inc.®

Northbrook, Illinois • (847) 272-8800

Melville, New York • (516) 271-6200

Santa Clara, California • (408) 985-2400

Research Triangle Park,
North Carolina • (919) 549-1400

Camas, Washington • (360) 817-5500

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 290698-76083
ISSUE DATE: June 29, 1998

Issued to: Rittal-Werke Rudolf Loh GmbH & Co. KG
Auf Dem Stuetzelberg
Postfach 1662, Herborn, GERMANY

Report Reference: March 31, 1986

This is to Certify that
representative samples of: DK-PS, PS, PC and MC Series Industrial Control
Panel Enclosures

Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s) indicated on this
Certificate.

Standard(s) for Safety: UL 508 Industrial Control Equipment

Box Type	Max Dimensions (mm)			Environmental Type(s)
	Width	Height	Depth	
PS	1800	2200	1000	1, 12
PS Stainless Steel	2100	2200	800	1, 12
DK-PS	2100	2200	800	1, 12
DK-PS w/Glazed Door	800	2200	800	1, 12
DK-PS w/Cable Entry	2100	2200	800	1
MC	1000	2200	800	1, 12
PS-EMC	1000	2200	800	1
PS-IVS	2100	2200	800	1, 12
PC-Based on PS	1200	2200	800	1, 12
PC Stainless Steel	2100	2200	800	1, 12
PC Operating Housing	600	800	600	1, 12

Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.

The UL Listing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or
abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" (UL); the word "Listed"; a control number (may be alphanumeric) assigned
by UL; and the product or category name (product identifier), as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: 
Underwriters Laboratories Inc.

Review Engineer: 
Underwriters Laboratories Inc.