

Certificate of Compliance

Certificate: 2460966

Master Contract: 153184

Project: 2460966

Date Issued: December 12, 2011

Issued to: **Rittal GmbH & Co. KG**
Auf dem Stuetzelberg 18
Herborn, 35745
Germany
Attention: Lars Martin

The products listed below are eligible to bear the CSA Mark shown



Wendy Zhu

Issued by: Wendy Zhu, Ph.D., P. Eng.

PRODUCTS

CLASS 3211 02 - INDUSTRIAL CONTROL EQUIPMENT - Kits

Filter fan kits, models SK3237.100, -110, -124, -600, -610, SK3238.100, -110, -124, -600, -610, SK3239.100, -110, -124, -600, -610, SK3240.100, -110, -124, -600, -610, SK3241.100, -110, -124, -600, -610, SK3243.100, -110, -600, -610, SK3244.100, -110, -140, -600, -610;

Filter kits, models SK3237.060, -200, SK3238.060, -200, SK3239.060, -200, SK3240.060, -200, SK3243.060, -200;

Filter fan hoods, models SK3237.080, SK3238.080, SK3239.080, SK3240.080, SK3243.080.

RATINGS

Model Series	Voltage	AC/DC	Frequency	Wattage	Max.ambient temp.
SK-	"V"	"Hz"	"Hz"	"W (50/60Hz)"	"°C"
3237.124	24	DC	-	3	40
3237.1	230	AC	50/60	9-Nov	60
3237.6					
3237.11	115	AC	50/60	9-Nov	60
3237.61					
3238.124	24	DC	-	4.1	55
3238.1	230	AC	50/60	19/18	60



Certificate: 2460966

Master Contract: 153184

Project: 2460966

Date Issued: December 12, 2011

3238.6					
3238.11	115	AC	50/60	20/18	60
3238.61					
3239.124	24	DC	-	4.1	55
3239.1	230	AC	50/60	19/18	60
3239.6					
3239.11	115	AC	50/60	20/18	60
3239.61					
3240.124	24	DC	-	10	40
3240.1	230	AC	50/60	35/34	40
3240.6					
3240.11	115	AC	50/60	35/34	40
3240.61					
3241.124	24	DC	-	19	40
3241.1	230	AC	50/60	40/42	40
3241.6					
3241.11	115	AC	50/60	40/42	40
3241.61					
3243.1	230	AC	50/60	70/87	40
3243.6					
3243.11	115	AC	50/60	75/90	40
3243.61					
3244.1	230	AC	50/60	95/135	40
3244.6					
3244.11	115	AC	50/60	100/145	40
3244.61					
3244.14	3 * 400	AC	50/60	93/130	40

Notes:

1. These devices have been evaluated for environmental Type Rating 12, if mounted according to manufacturers instructions as Illustration in CSA Test Report.
2. The devices SK 3238, SK 3239, SK 3240, SK 3241, SK 3243 and SK 3244 have been evaluated for environmental Type Rating 12, 3R, 3 and 4X, when used with the filter fan hoods and if mounted according to manufacturers instructions.
3. The device SK 3237, has been evaluated for environmental Type Rating 12 and 3R, when used with the filter fan hoods and if mounted according to manufacturers instructions.



Certificate: 2460966

Master Contract: 153184

Project: 2460966

Date Issued: December 12, 2011

4. The suitability of these fans for use with a solid state control has not been evaluated.

5. Models with 24V motors described in this Report, shall be used in circuits supplied by Limited Voltage / Limited Current circuits and motor overload protection shall be provided.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 14-10 - Industrial Control Equipment

CAN/CSA C22.2 No. 94 -M91/06 - Special Purpose Enclosures