

# CERTIFICATE

## Rittal quality management

Herewith we confirm that the design of the Rittal enclosure VX25 and VX IT:  
8840.100, 8840.110, 8840.120, 8840.130, 5306.190, 5307.190, 5308.190,  
5309.190, 5325.190, 5326.190, 5327.190, 5328.190, 5329.190, 5330.190,  
5331.190, 5326.131, 5303.134, 5329.131, 5330.133, 5307.134, 5309.136

with screwed sidewalls, comply with the requirements according  
to UL 50E, 3rd Ed. Oct. 2020, Type 12 (NEMA 12) and fulfil the  
protection category IP55 according to EN 60529:1991+A1:2000+A2:2013

<sup>a</sup>Degrees of protection provided by enclosures.



Fabian Werner  
Quality Management Laboratory

18.07.2024

24RDL054

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES