

# Rittal – The System.

Faster – better – everywhere.



## DK 5301.453

## Aluminium/sheet steel door, vented

State: 16/08/2025 (Source: [rittal.com/com-en](https://www.rittal.com/com-en))

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

FRIEDHELM LOH GROUP



# DK 5301.453 - Aluminium/sheet steel door, vented for VX IT

To replace existing doors. The vented surface area is approx. 85% perforated.



## Features

|                      |   |
|----------------------|---|
| Model No.            | DK 5301.453   |
| Product description  | To replace existing doors. The vented surface area is approx. 85% perforated.   |
| Material             | Frame: Extruded aluminium section<br>Vent grille: Sheet steel<br>Vertical extrusion: Aluminium, anodised<br>Horizontal extrusion: Aluminium, spray finished |
| Colour               | Comfort handle VX, hinges, horizontal extrusion, vent grille: RAL 9005<br>Vertical profile: silver coloured   |
| Supply includes      | Door with comfort handle for semi-cylinders with security lock 3524 E<br>3 x 180° hinges, fitted<br>Assembly parts  |
| Assembly instruction | For a door opening angle of 180° when baying, a 180° baying hinge is required   |

# Features

|                               |  |
|-------------------------------|--|
| Note                          | Door opening angle for stand-alone siting: max. 240°<br>Door opening angle when baying: max. 105°              |
| To fit                        | Enclosure type: VX IT<br>Width: = 800 mm<br>Height: = 2,200 mm   |
| Packs of                      | 1 pc(s).   |
| Net weight                    | 9.6  |
| Gross weight                  | 10.6   |
| PCF per pack (cradle-to-gate) | 40.4 kg CO2 eq (Cat B)   |
| Note on PCF category          | Category B: PCF value (cradle-to-gate) based on the product weight, approximately calculated and self-declared |
| EAN                           | 4028177955073  |
| ETIM 9                        | EC000747   |
| ECLASS 8.0                    | 27182204   |