

Rittal – The System.

Faster – better – everywhere.



The screenshot displays the RiZone software interface. On the left, a tree view shows the hierarchy: AC4DC > Rittal > Haiger > RiMatrixS > Container1 > Schrankreihe > Schrank1-7. Below this, various sensors and components are listed, including R6_Pressure, R4_Pressure, R2_Pressure, C1_T_kalt, C2_T_kalt, C3_T_kalt, PMC-120, PSM-MID-M16, and power/cooling modules. The main window shows a table of variables with columns for ID, Name, Value, Unit, and Maintenance group. The table lists various water control and cooling capacity parameters, with some rows highlighted in red. Below the table, a message log shows monitoring events with columns for Timestamp, Elapsed time, Process, Owner, State, and Description.

ID	Name	Value	Unit	Maintenance group
20293	Water.Control-Valve.DescName	Control-Valve		Set
20294	Water.Control-Valve.ActualValue	66	%	
20296	Water.Control-Valve.Status	OK		
20501	Water.Cooling Capacity.DescName	Cooling-Capacity		Set
20502	Water.Cooling Capacity.Value	0	W	
20304	Water.Cooling Capacity.Status	OK		
20503	Water.Leakage Sensor.DescName	Leakage		Set
20301	Water.Leakage Sensor.Input	0		
20312	Water.Leakage Sensor.Status	OK		
20504	Water.Condensate Sensor.DescName	Condensate		Set
20505	Water.Condensate Sensor.Input	0		
20506	Water.Condensate Sensor.Pump	0		
20306	Water.Condensate Sensor.Cycles	0		
20307	Water.Condensate Sensor.Duration	0	s	
20316	Water.Condensate Sensor.Status	Off		
20310	Config.Fans.Command	Manual		Set
20311	Config.Control-Valve.Command	Manual		Set
20507	Config.Fans.Fan1	55	%	Set
20508	Config.Fans.Fan2	55	%	Set
20263	Config.Fans.Fan3	55	%	Set
20509	Config.Fans.Fan4	55	%	Set
20314	Config.Fans.Fan5	55	%	Set
20315	Config.Fans.Fan6	55	%	Set
20510	Config.Control-Valve.Valve	65	%	Set

Timestamp	Elapsed time	Process	Owner	State	Description
6/27/2013 10:36:48 AM		Monitoring PU-T2 1963			
6/27/2013 10:36:48 AM		Monitoring R6_T_warm_mitte 11381			
6/27/2013 10:36:47 AM		Monitoring R6_T_warm_mitte 11381			
6/27/2013 10:35:44 AM	> 1 Min.	Monitoring LCP 20209			
6/27/2013 10:32:27 AM	> 4 Min.	Monitoring LCP 20209			
6/27/2013 10:16:38 AM	> 20 Min.	Monitoring LCP 20209			
6/27/2013 10:16:19 AM	> 20 Min.	Monitoring PU-LCP 2214			
6/27/2013 10:16:26 AM	> 22 Min.	Monitoring R6_L2_B 10591			

DK 7990.402

RiZone-Appliance Standard

Estado: 9/06/2026 (Fuente: rittal.com/es-es)

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

FRIEDHELM LOH GROUP



DK 7990.402 - RiZone-Appliance Standard

RiZone se suministra como appliance de software.

Características

Referencia	DK 7990.402
Descripción producto	RiZone se suministra como appliance de software. La appliance de software se ofrece como servidor virtual en formato Open Virtualization (OVF), pudiéndose utilizar con hardware existente en el centro de datos.
Modificación de producto	RiZone Appliance se entrega con la versión 3.5 de RiZone. Como sistema operativo soporta el actual sistema operativo Microsoft Server 2012R2. La base de datos local se basa en SQL Express 2012.
Observación	RiZone soporta los protocolos SNMP V1/V2C y SNMP V3 para la monitorización de los componentes de la infraestructura (dispositivos OT) de un centro de datos. RiZone no está sujeto a ningún fabricante y es adecuado para su uso en un entorno heterogéneo de dispositivos OT.
Unidad de embalaje	1 pza(s).
Código arancelario	85234920
ETIM 9	EC000501
ECLASS 8.0	19240201
Descripción producto	DK RiZone-Appliance Standard, software installer: RiZone Software, 1 P.