

# Rittal – The System.

Faster – better – everywhere.



## SV 9676.007 Spacer

State: 4/8/2025 (Source: [rittal.com/in-en](https://www.rittal.com/in-en))

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

FRIEDHELM LOH GROUP



# SV 9676.007 - Spacer

When using smaller busbar widths, the spacer piece should be inserted into the chambers of the support to compensate for width differences.

## Features

Model No.	SV 9676.007
Position of the bar system in the functional space	2 1 2
Note	At a bar width of < 60 mm for Flat-PLS 60 or < 100 mm for Flat-PLS 100, spacers must be used.
To fit busbar system	Flat-PLS 60 Flat-PLS 100
To fit busbars	Flat copper busbars Flat copper busbars Flat copper busbars
To fit busbars	Width: 40, 50, 80 Height: 10, 10, 10 mm
Packs of	16 pc(s).
Net weight	0.064
Gross weight	0.081
Customs tariff number	73269098
EAN	4028177599437
ETIM 9	EC001900
ECLASS 8.0	27400613

## Approvals

# Approvals

---

Approvals

ABS

DNV-GL

Lloyds Register of Shipping