

Rittal – The System.

Faster – better – everywhere.



RiZone [User=Thorsten, Server=rizoneac4dc, Mode=View]

Project Edit Views Charts Workflows Reports Administration Help

Location Devices

AC4DC

Rittal

Haiger

RiMatrixS

Container1

Schrankreihe

Schrank1

Schrank2

Schrank3

Schrank4

Schrank5

Schrank6

Schrank7

Gesamt Leistungsaufnahme

USV Leistungsaufnahme

Chiller Leistungsaufnahme

R6_Pressure

R4_Pressure

R2_Pressure

C1_T_kalt

C2_T_kalt

C3_T_kalt

PMC-120

PSM-MID-M16

Einspeisung Gesamt

Einspeisung USV

Einspeisung Klima

USV Modul aus

Last zur Batterie

Batterie Ladung ein

EPO_USV

Schema

[17957] QM-T: Views [20209] LCP: Variables [17957] QM-T: Charts

Group Find variable:

ID	Name	Value	Unit	Maintenance group
20293	Water.Control-Valve.DescName	Control-Valve		Set
20294	Water.Control-Valve.ActualValue	66	%	
20296	Water.Control-Valve.Status	OK		
20501	Water.Cooling Capacity.DescName	Cooling-Capacity		Set
20502	Water.Cooling Capacity.Value	0	W	
20304	Water.Cooling Capacity.Status	OK		
20503	Water.Leakage Sensor.DescName	Leakage		Set
20301	Water.Leakage Sensor.Input	0		
20312	Water.Leakage Sensor.Status	OK		
20504	Water.Condensate Sensor.DescName	Condensate		Set
20505	Water.Condensate Sensor.Input	0		
20506	Water.Condensate Sensor.Pump	0		
20306	Water.Condensate Sensor.Cycles	0		
20307	Water.Condensate Sensor.Duration	0	s	
20316	Water.Condensate Sensor.Status	Off		
20310	Config.Fans.Command	Manual		Set
20311	Config.Control-Valve.Command	Manual		Set
20507	Config.Fans.Fan1	55	%	Set
20508	Config.Fans.Fan2	55	%	Set
20263	Config.Fans.Fan3	55	%	Set
20509	Config.Fans.Fan4	55	%	Set
20314	Config.Fans.Fan5	55	%	Set
20315	Config.Fans.Fan6	55	%	Set
20510	Config.Control-Valve.Valve	65	%	Set

Live messages Terminated messages

Category filter on current list: Show all messages categories from current list Timespan filter on current list: All Status filter on current list:

Timestamp	Elapsed time	Process	Owner	State	Description
(7) 6/27/2013 10:36:48 AM		Monitoring PU-T2 1963			
(3) 6/27/2013 10:36:48 AM		Monitoring R6_T_warm_mitte 11381			
(2) 6/27/2013 10:36:47 AM		Monitoring R6_T_warm_mitte 11381			
(5) 6/27/2013 10:35:44 AM	> 1 Min.	Monitoring LCP 20209			
(5) 6/27/2013 10:32:27 AM	> 4 Min.	Monitoring LCP 20209			
(1) 6/27/2013 10:16:38 AM	> 20 Min.	Monitoring LCP 20209			
(2) 6/27/2013 10:16:19 AM	> 20 Min.	Monitoring PU-LCP 2214			
(7) 6/27/2013 10:16:26 AM	> 22 Min.	Monitoring R6_L2 R 10591			

Component

ID 20209

Name LCP

Model number 3311.260

Component type LCP

Description

Temperature unit CELSIUS

Device index 2

Driver description

Name Rittal_Sensor_Generic

Version 1.1.0

Supported devices see documentation for a list of supported

DK 7990.103

RiZone 애플리케이션 표준

상태: 2024. 5. 17 (원천: rittal.com/kr-ko)

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

FRIEDHELM LOH GROUP



DK 7990.103 - RiZone 애플리케이션 표준

RiZone은 응용 소프트웨어 형태로 제공.

특징

주문 번호	DK 7990.103
버전	소프트웨어 애플리케이션: 하드 드라이브 + Windows
제품 설명	RiZone은 소프트웨어 기기로 제공됩니다. 소프트웨어 기기는 데이터 센터 내 기존 하드웨어에서 원활하게 사용할 수 있는 OVF(Open Virtualization Format)의 가상 서버로 제공됩니다.
Product modification	RiZone Appliance는 RiZone의 3.5 버전으로 공급됨. 운영 시스템으로 최신 Microsoft 서버 운영 시스템 2012R2가 지원됨. 로컬 데이터베이스는 SQL Express 2012를 사용함.
참고 사항	RiZone은 데이터 센터의 인프라 구성요소(OT 장치)를 모니터링하기 위한 SNMP V1/V2C와 SNMP V3 프로토콜을 지원함. RiZone은 제조사와 상관 없이 다른 OT 장치 환경에서도 사용할 수 있음.
포장 단위	1 개
중량/개수	0.64 kg
관세 번호	85234920
EAN	4028177665675
ETIM 7.0	EC000501
ECLASS 8.0	19240201