

# Rittal – The System.

Faster – better – everywhere.



## SV 9676.007

## Spacer

State: 12/05/2026 (Source: [rittal.com/nz-en](http://rittal.com/nz-en))

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

FRIEDHELM LOH GROUP



# SV 9676.007 - Spacer

When using smaller busbar widths, the spacer piece should be inserted into the chambers of the support to compensate for width differences.

## Features

Model No.	SV 9676.007
Position of the bar system in the functional space	2 1 2
Note	At a bar width of < 60 mm for Flat-PLS 60 or < 100 mm for Flat-PLS 100, spacers must be used.
To fit busbar system	Flat-PLS 60 Flat-PLS 100
To fit busbars	Flat copper busbars Flat copper busbars Flat copper busbars
To fit busbars	Width: 40, 50, 80 Height: 10, 10, 10 mm
Packs of	16 pc(s).
Net weight	0.064 kg
Gross weight	0.081 kg
Customs tariff number	73269098
ETIM 9	EC001900
ECLASS 8.0	27400613
Product description	SV Spacer, for busbar support, SV 9676002/004/020/21, for busbar WH: 40/50/80x10 mm

## Approvals

# Approvals

---

Approvals

ABS

DNV

Lloyds Register