


Rittal – The System.

Faster – better – everywhere.



TS 3313.100

Cable management enclosure

State: 01/09/2025 (Source: [rittal.com/uae-en](https://www.rittal.com/uae-en))

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

FRIEDHELM LOH GROUP



TS 3313.100 - Cable management enclosure for TS IT

For laying, securing and storing cables or as an empty enclosure with uneven LCP installations.

Features

| | |
|---------------------|---|
| Model No. | TS 3313.100 |
| Product description | For laying, securing and storing cables or as an empty enclosure with uneven Liquid Cooling Package (LCP) installations. |
| Benefits | Optimum accommodation of surplus cables and structured cable management |
| Applications | As a cable management rack between fully configured network and server racks As an empty enclosure for symmetrical balancing in cold/hot aisle containment with an uneven number of LCPs in two enclosure suites As a placeholder for easy retrofitting of LCP installations |
| Material | Sheet steel Aluminium |
| Surface finish | Enclosure frame: Dipcoat-primed Doors and roof: Dipcoat-primed, powder-coated |
| General colour | RAL 7035 |
| Colour | Enclosure: RAL 7035 Front: RAL 9005 |
| Supply includes | Enclosure frame with front and rear door Aluminium door, front, solid with black designer trim panel, 180° hinges Sheet steel door at the rear, solid, 180° hinges Lock front and rear: Comfort handle for profile half-cylinders and security lock 3524 E 2 roof/base plates, with cut-outs for cable entry via brush strips 3 TS punched sections with mounting flanges mounted on the left and right Baying seal |

Features

| | |
|----------------|---|
| Dimensions | Width: 300 mm Height: 2,000 mm Depth: 1,000 mm |
| Note | For positioning at the start/end of an enclosure suite, a side panel will be required |
| Basic material | Aluminium |
| Packs of | 1 pc(s). |
| Net weight | 87.4 |
| Gross weight | 92 |
| EAN | 4028177708013 |
| ETIM 9 | EC000721 |
| ETIM 8 | EC000721 |
| ECLASS 8.0 | 27182003 |

Approvals

| | |
|--------------|---|
| Explanations | Declaration of conformity Declaration of conformity UK |
|--------------|---|