

# Rittal – The System.

Faster – better – everywhere.



## SV 9676.007

## Spacer

State: 8/12/2025 (Source: [rittal.com/uk-en](http://rittal.com/uk-en))

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

FRIEDHELM LOH GROUP



# SV 9676.007 - Spacer

When using smaller busbar widths, the spacer piece should be inserted into the chambers of the support to compensate for width differences.

## Features

|  |   |
|--|---|
| Model No.  | SV 9676.007   |
| Position of the bar system in the functional space | 2<br>1<br>2   |
| Note   | At a bar width of < 60 mm for Flat-PLS 60 or < 100 mm for Flat-PLS 100, spacers must be used. |
| To fit busbar system                               | Flat-PLS 60<br>Flat-PLS 100   |
| To fit busbars                                     | Flat copper busbars<br>Flat copper busbars<br>Flat copper busbars                             |
| To fit busbars                                     | Width: 40, 50, 80<br>Height: 10, 10, 10 mm  |
| Packs of   | 16 pc(s).   |
| Net weight   | 0.064   |
| Gross weight                                       | 0.081   |
| Customs tariff number                              | 73269098  |
| EAN  | 4028177599437   |
| ETIM 9   | EC001900  |
| ECLASS 8.0   | 27400613  |

## Approvals

# Approvals

---

Approvals

ABS

DNV-GL

Lloyds Register of Shipping